

DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
 QUALITY CONTROL LABORATORY
 TRANS YAMUNA REGION TAHIRPUR DELHI-110093



NO: DJB/ACWA(TYR)/2021/11026

DATE:- 17-08-2021

Analysis report of DJB supply water samples collected from (1) Inlet and (2) Outlet Queen Global International School, C-Block, Dilshad Garden, Delhi- 95 for drinking purpose, M/S Principal.

Ref. No:- Nil,

Challan No:-102

dated:- 11-08-2021

Date of collection:-12-08-2021

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
3.	Colour	---	---	-	Clear	Clear
4.	Odour	---	---	-	Chlor.	Chlor.
5.	Turbidity	1.0	5.0	NTU	1.12	1.21
6.	P ^H Value	6.5-8.5	--	-	7.5	7.6
7.	Electrical Conductivity	--	--	µs/cm	208	210
8.	Total Dissolved Solids	500	2000	mg/l	135	136
B.	Chemical Examination					
9.	P ^H Alkalinity	45	NO RELAXATION	mg/l	NIL	NIL
10.	Total Alkalinity	200	600	mg/l	68	70
11.	Total Hardness	200	600	mg/l	82	82
12.	Calcium Hardness	---	---	mg/l	58	58
13.	Magnesium Hardness	---	---	mg/l	24	24
14.	Calcium as (Ca)	75	200	mg/l	23.2	23.2
15.	Magnesium as (Mg)	30	100	mg/l	5.76	5.76
16.	Ammonical Nitrogen	0.5	NO RELAXATION	mg/l	N.D	N.D
17.	Nitrite	---	---	mg/l	N.D	N.D
18.	Nitrate	45	NO RELAXATION	mg/l	3.59	3.87
19.	Sulphate	200	400	mg/l	19.9	22.8
20.	Chloride	250	1000	mg/l	12	12
21.	Fluoride	1.0	1.5	mg/l	1.41	1.49
22.	Total Iron	1.0	NO RELAXATION	mg/l	0.12	0.12
23.	Cyanide	0.05	NO RELAXATION	mg/l	N.D.	N.D.
24.	Residual Chlorine	0.2	1.0	mg/l	1.0	0.75
C.	Bacteriological Examination					
25.	Coliform count	Absent	NO RELAXATION	MPS/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conforms BIS: 10500-2012 and can be considered fit for drinking purpose.

[Signature]
 CHEMIST

[Signature]
 CHEMIST

[Signature]
 ACWA (TYR)

[Signature]
 Principal
 Queen Global International School
 C-Block, Main Road,
 Dilshad Garden, Delhi-110095

[Signature]
 MANAGER
 QUEEN GLOBAL INTERNATIONAL SCHOOL
 C-BLOCK, MAIN ROAD, DILSHAD GARDEN
 DELHI-110095
[Signature]
 Authorised Signatory

EAST DELHI MUNICIPAL CORPORATION
PUBLIC HEALTH DEPARTMENT
SHAHDARA (NORTH) ZONE

No.DHO/Shah/N/2021/ 395

Dated: 18/8/2021


SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary No. 1186 dated 10.08.2021, the inspection of 'QUEEN GLOBAL INTERNATIONAL SCHOOL' situated at C-Block, Main Road, Dilshad Garden, Delhi-110095 was carried out on dated 17.08.2021. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant 'PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW' to the above-said school. This certificate is valid for a period of one year from the date of issue.

Manager
QUEEN GLOBAL INTERNATIONAL SCHOOL
C-Block, Main Road, Dilshad Garden
Delhi-110095


Principal
Queen Global International School
C-Block, Main Road,
Dilshad Garden, Delhi-110095


Dy. Health Officer
Shahdara (North) Zone

Dy. Health Officer
Shahdara (North) Zone
East Delhi Municipal Corporation


MANAGER
QUEEN GLOBAL INTERNATIONAL SCHOOL
C-BLOCK, MAIN ROAD DILSHAD GARDEN
DELHI-110095